

San Joaquin Valley Unified Air Pollution Control District

PERMIT UNIT: C-447-9-1

EXPIRATION DATE: 6/30/2000

EQUIPMENT DESCRIPTION:

ONE 500 GALLON ABOVE GROUND STORAGE TANK SERVED BY CONVAULT PHASE I VAPOR RECOVERY SYSTEMS G-70-97A WITH ONE GASOLINE DISPENSING NOZZLE; EXEMPT FROM PHASE II.

Permit Unit Requirements

1. Total gasoline throughput for the facility shall not exceed 10,000 gallons per any consecutive 30-day period nor 24,000 gallons per calendar year. [District Rule 4622, 4.1, Exemptions] Federally Enforceable Through Title V Permit
2. Records of monthly gasoline throughput shall be maintained, retained on the premises for a period of at least five years and as long as exempt status is claimed. These records shall be made available for District inspection upon request and allow the gasoline throughput for any 30-day period to be continuously determined. [District Rule 2520, 9.5.2 and 4622, 6.1.1] Federally Enforceable Through Title V Permit
3. If the gasoline throughput exceeds either 10,000 gallons per any consecutive 30-day period or 24,000 gallons per calendar year, then the facility shall notify the District within 30 days. [District Rule 4622, 6.1.2] Federally Enforceable Through Title V Permit
4. Each storage tank subject to this permit shall be equipped with an ARB certified Phase I vapor recovery system, which shall prevent at least 95% by weight of all gasoline vapors displaced during the filling of storage tanks from entering the atmosphere. The transfer of gasoline from any delivery vessel to any stationary storage container with 250 gallon capacity or more shall not be allowed unless the container is equipped with a permanent submerged fill pipe and an ARB certified Phase 1 system, which is maintained and operated according to manufacturers specifications. [District Rule 4621, 3.1 and 5.1.1] Federally Enforceable Through Title V Permit
5. Compliance with the requirement of the Phase I system to be 95% effective for displaced vapors is considered to be demonstrated by passing performance tests, at least once every 5 years from the date of the most recent test or at more frequent intervals, as specified by the ARB Executive Order certifying the system. Facilities that have not been performance tested previously, using the following applicable methods, shall be tested in accordance with BAAQMD Source Test Procedure ST-30 (Static Leak Test Procedure Underground Tanks)

or ST-38 (Static Leak Test Procedure Aboveground Tanks) no later than 90 days of issuance of this permit. [District Rules 2520, 9.4.2] Federally Enforceable Through Title V Permit

6. Each aboveground storage tank shall be equipped with a pressure-vacuum valve set to within 10% of the maximum allowable working pressure of the tank. No gasoline shall be placed, stored, or held in any above-ground tank of 250 gallon capacity or more unless it is so equipped. [District Rule 4621, 5.1.2; 4623, 5.4] Federally Enforceable Through Title V Permit

7. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo tank which attest to the vapor integrity of the tank. [District Rule 4621, 5.2.1] Federally Enforceable Through Title V Permit

8. No gasoline shall be transferred into any gasoline stationary storage tank subject to this permit if the vapor recovery system contains an inoperative dry break until it is repaired, replaced, or adjusted as necessary to correct the defect. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4621 except section 5.2.2 (as amended May 20, 1993), 4622, section 6.1 (as amended February 17, 1994), and 4623, section 5.4 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

10. The requirements of County Rules 412.1 (Kern and Tulare), 411.1 (Stanislaus and Merced), 411.2 (San Joaquin), 412 (Fresno, Kings, Stanislaus, Merced, and San Joaquin), 413 (Kern and Tulare), and 419 (Madera) do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

11. The requirements of District Rules 4403 (as amended February 16, 1995), 4622, except section 6.1 (as amended February 17, 1994), 4623, except section 5.4 (as amended December 17, 1992), and 4624 (as amended December 17, 1992) do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

12. The requirements of 40 CFR 60 Subparts XX do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit